

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No. : TR/WTL/PHD/PWD/PDY/2025/W-0770

Date: 18.08.2025

TEST REPORT- CHEMICAL

Customer Name & Address : Vaasavi International School - CBSE,
No.401, M.G.Road, Muthialpet, Puducherry - 605003.
Customer Reference : Letter No.VIS/CBSE/2025-26/08/003 dt.13.08.2025

Page 1 of 1


SAMPLE DETAILS

Sample Code	: 2025/W-0770	Information provided by the Customer	
Product Category	: Water	Sampled on	: 13.08.2025
Sample Name	: Drinking Water	Sample Description	: Treated Water (R.O.Water)
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 1
Sample Received on	: 13.08.2025	Sampling Location	School Campus, No.401, M.G.Road, Muthialpet, Puducherry.
Test Started on	: 13.08.2025		
Test Completed on	: 20.08.2025		

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 24th Edition, 2023, 4500-H+B	--	7.11	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 24th Edition, 2023, 2510 B	µs/cm	74.6	---	---
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	46.3	500 Max	2000 Max

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY.

Copy submitted to:
The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.